



Xtralis VESDA VFT-15 detectors are multi-channel microbore air-sampling systems with an alarm sensitivity range from 0.01% to 20% obscuration/m (0.003% to 6.10% obscuration/ft). These detectors are classified as Very Early Warning Smoke Detectors and can reliably detect fire at an early stage, and low to high concentrations of smoke. As a multi-channel system, the VFT detector is able to divide a protected space into sampling sectors, enabling the localization of a fire for faster incident response.

The detectors are configurable for a variety of environments, providing ideal fire detection solutions for cabinets, Electronic Data Processing (EDP) rooms, prisons, historic houses, custody suites, museums and art galleries.

How it works

The VFT detector draws a combined air sample from a network of microbore flexible tubing from all sectors in the protected area, then filters and analyzes the sample in a laser detection chamber. When smoke particles are detected and the smoke level reaches a TRACE alarm threshold, the system will sequentially scan the sectors via the rotary valve to identify the sector, or sectors, with the smoke condition. Alarm states (Alert, Action, Fire 1 and Fire 2) are shown on the display and communicated to a host fire alarm control panel.

Product Features

Programming and Configuration

Four independent alarm levels are available for each channel. The smoke thresholds and delays for each of these alarms can be individually programmed per sector. VFT detectors provide a simple and comprehensive display that includes an LED array to show the measured smoke level for the currently selected microbore, and an on-board programmer for local configuration.

RS232, RS485 and TCP/IP communication interfaces are available to connect to Xtralis Configuration and Fire System Management software packages: Xtralis VSC and Xtralis VSM4. RS485 interfaces also allow connections to programming devices and remote displays, and the TCP/IP Ethernet interface can provide access to an email messaging service.

Inputs and Outputs

VFT detectors support a number of additional modules. These provide the detector with programmable output relay interfaces and 4 to 20 mA analog outputs. A Remote Display panel can also be connected at a distance of up to 1 km away from the main VFT detector.

Features

- 15 pipe air sampling
- 0.01% to 20% obscuration/m (0.003% to 6.10% obscuration/ft)
- 4 Alarms - Alert, Action, Fire 1, Fire 2
- 15 x 50 m (15 x 164 ft) microbore sampling pipe
- Enhanced 0.7 bar rotary vane vacuum pump
- Ethernet TCP/IP
- RS232 and RS485 Modbus
- 5 relay outputs and expandable
- Optional relay module and 4 to 20 mA analog outputs module
- Area coverage of up to 1500 m² (16 150 ft²)

Listings/Approvals


- FM
- VdS
- CE - EMC, LVD and CPD
- EN54-20
 - Class A: 0.1% obs/m (0.03% obs/ft)
 - Class B: 0.1% obs/m (0.03% obs/ft)
 - Class C: 1.0% obs/m (0.3% obs/ft)
- *VFT-15 detectors have one sampling hole per microbore tube.*
- Major Agency Approvals pending

Regional approvals listings and regulatory compliance vary between Xtralis VESDA models.

Aspiration and Flow Sensing

The aspirator is a 0.7 bar rotary vane vacuum pump, which provides superior detection times over long pipe lengths and reliable detection in high air flow environments. Airflow in each pipe is monitored by a differential pressure sensor, with airflow faults indicated on the display and to monitoring equipment.

Dimensions



Ordering Information

24 VDC, Display/Programmer, TCP/IP, 15 inlets, Class A/B/C, 0.01 to 20% obs/m (0.003 to 6.1% obs/ft)

VFT-15

24 VDC, Display/Programmer, TCP/IP, 15 inlets, Class C, 1 to 20% obs/m (0.3 to 6.1% obs/ft)

VFT-15-C

4-Channel Relay Module

01-E606-01

8-Channel 4-20 mA Re-Transmission Module

01-E624-01

Remote Display

01-V921-15

*Note: The 8-Channel Re-Transmission module is currently not approved. Please contact your nearest Xtralis office for more information.

Specifications

Supply Voltage:

Nominal 24 VDC

Supply Current at 24 VDC:

	Quiescent	Scanning
Power	31.2 W	55.9 W
Current	1.30 A	2.33 A

Aspirator:

0.7 bar rotary vane vacuum pump

Dimensions (WHD):

490 mm x 355 mm x 200 mm
(19.3 in. x 14.0 in. x 7.9 in.)

Operating Conditions:

Tested to:

-10 to 55 °C (14 to 131 °F)

Recommended Detector Ambient:

0 to 39 °C (32 to 103 °F)

Sampled Air:

-20 to 60 °C (4 to 140 °F)

Humidity:

10 to 95% RH (non-condensing)

Please consult your Xtralis office for operation outside these parameters or where sampled air is continually above 0.05% obs/m (0.015% obs/ft) under normal operating conditions.

Microbore Size:

Outer Diameter: 6 mm

Inner Diameter: 4 mm

Microbore Length:

15 x 50m (15 x 164 ft)

Pipe Length: 50 m (max)

Alarm Sensitivity Range:

0.01 to 20 % obs/m

(0.003 to 6.10 % obs/ft)

Alarm Settings:

Alarm levels: Alert, Action, Fire 1 and Fire 2

Individually programmable for each level

IP Rating:

IP30

Filtration:

Cartridge dust particle filter

Flow Monitoring:

Differential pressure sensor

Relay Outputs:

4 alarm relays, 1 fault relay

Rated 2 A @ 30 VDC NO/NC Contacts

Communication:

Modbus over RS232, RS485 and

TCP/IP

The contents of this document are provided on an "as is" basis. No representation or warranty (either express or implied) is made as to the completeness, accuracy or reliability of the contents of this document. The manufacturer reserves the right to change designs or specifications without obligation and without further notice. Except as otherwise provided, all warranties, express or implied, including without limitation any implied warranties of merchantability and fitness for a particular purpose are expressly excluded.

This document includes registered and unregistered trademarks. All trademarks displayed are the trademarks of their respective owners. Your use of this document does not constitute or create a licence or any other right to use the name and/or trademark and/or label.

This document is subject to copyright owned by Xtralis AG ("Xtralis"). You agree not to copy, communicate to the public, adapt, distribute, transfer, sell, modify or publish any contents of this document without the express prior written consent of Xtralis.